This document gives pertinent information concerning the issuance of the VPDES Permit listed below. This permit is being processed as a Minor, Municipal permit. The discharge results from the operation of a 0.0055 MGD wastewater treatment plant. The effluent limitations and special conditions contained in this permit will maintain the Water Quality Standards of 9 VAC 25-260-00 et seq.

1.	Facility Name and Mailing Address:	Camp Red Arrow WWTP 578 Covered Bridge Dr. Madison, VA 22727	SIC Code :	4952
	Facility Location:	19262 Mulford Camp Road Culpeper, VA 22701	County:	Culpeper
	Facility Contact Name:	Perry Utz Director	Telephone Number:	540-948-3029
2.	Permit No.:	VA0092452	Expiration Date of previous permit:	New Issuance
	Other VPDES Permits associated with this facility:		N/A	
	Other Permits associated with this facility:		N/A	
	E2/E3/E4 Status:	N/A		
3.	Owner Name:	Children's Bible Ministries of Virginia, Inc.		
	Owner Contact/Title:	Perry Utz, Director	Telephone Number:	540-948-3029
4.	Application Complete Date:	January 14, 2009		
	Permit Drafted By:	Susan Oakes	Date Drafted:	March 31, 2009
	Draft Permit Reviewed By:	Alison Thompson	Date Reviewed:	April 7, 2009
	Public Comment Period :	Start Date: December 24, 2009	End Date:	January 22, 2010

5. Receiving Waters Information: See **Attachment 1** for the Flow Frequency Determination

Receiving Stream Name :	Mountain Run, UT		
Drainage Area at Outfall:	0.09 sq.mi.	River Mile:	8.8
Stream Basin:	Rappahannock River	Subbasin:	Rappahannock
Section:	4	Stream Class:	III
Special Standards:	None	Waterbody ID:	VAN-E09R
7Q10 Low Flow:	0 MGD	7Q10 High Flow:	0 MGD
1Q10 Low Flow:	0 MGD	1Q10 High Flow:	0 MGD
Harmonic Mean Flow:	0 MGD	30Q5 Flow:	0 MGD
303(d) Listed:	No	30Q10 Flow:	0 MGD
TMDL Modification Approved:	Yes	Date TMDL Modification Approved:	October 29, 2009

6. Statutory or Regulatory Basis for Special Conditions and Effluent Limitations:

- ✓ State Water Control Law
- ✓ Clean Water Act
- ✓ VPDES Permit Regulation
- ✓ EPA NPDES Regulation
- ✓ EPA Guidelines
- ✓ Water Quality Standards
- ___ Other

7. Licensed Operator Requirements: Class III

8. Reliability Class: Class II

9. Permit Characterization:

✓ Private	✓ Effluent Limited	___ Possible Interstate Effect
___ Federal	✓ Water Quality Limited	___ Compliance Schedule Required
___ State	___ Toxics Monitoring Program Required	___ Interim Limits in Permit
___ POTW	___ Pretreatment Program Required	___ Interim Limits in Other Document
✓ TMDL		

10. Wastewater Sources and Treatment Description:

This facility is not built. The proposed system will serve a bible camp for children with an estimated maximum population of 200 campers per day with 20 staff per day. The camp will operate during summer months and several weekends during the year. The site will have a camp office, check-in building, three cabins, dining hall, nurses station, bath house, swimming pool and pool pump house. The proposed system will consist of a dual train treatment system. The system will contain a grease trap tank (trash tank), septic tank, two 2,500 gallon trash tanks, two 3,000 gpd Fixed Film Delta Treatment units, two 5,000 gallon pump tanks, two single pass sand filters, two UV disinfection units and a discharge pump tank. The treated and disinfected effluent will then enter a 500 gallon re-aeration chamber. All effluent sampling is to be conducted at the sample chamber located after the re-aeration chamber. The effluent will then discharge to the unnamed tributary where it will make its way to Mountain Run.

The swimming pool volume is estimated to be 199,000 gallons. The pool will not be emptied and will be covered during the off-season. It is expected that the pool will be in use between Memorial Day and Labor Day. Swimming pool filtration will be accomplished via sand filters. The pool filter backwash will seasonally discharge approximately 2,500 to 3,000 gallons of water every seven (7) to ten (10) days depending upon numbers of bathers. The pool water will be disinfected using chlorine. Chlorine levels are expected to range between 1 – 3 ppm. The filter backwash will be dechlorinated prior to discharging to the dosing tank.

See **Attachment 2** for a facility schematic/diagram.

TABLE 1 – Outfall Description

Outfall Number	Discharge Sources	Treatment	Design Flow	Outfall Latitude and Longitude
001	Domestic and Industrial Wastewater	See Item 10 above.	0.0055 MGD	**38° 26' 37.4"** N **77° 50' 39.8"** W
See **Attachment 3** for (Germanna Bridge, DEQ #184A) topographic map.				

11. Sludge Treatment and Disposal Methods:

Sludge will be pumped periodically and hauled offsite by Septiclean, Inc. to the Town of Culpeper Wastewater Treatment Facility (VA0061950), for final treatment and disposal.

12. Discharges, Intakes, Monitoring Stations, Other Items in Vicinity of Discharge

TABLE 2

Station Number	Ambient Monitoring Stations
3-MTN000.59	DEQ Ambient and Biological Monitoring Station located on Mountain Run at the Rt. 620 bridge crossing, approximately 9.7 miles downstream of the outfall.
3-MTN003.31	Freshwater Probabilistic Monitoring Station downstream from Rt. 672.
3-MTN005.79	Fish Tissue/Sediment Station at Rt. 620/672.

13. Material Storage: Not applicable. The facility has not been built.

14. Site Inspection: Performed by Susan Oakes and Alison Thompson on February 11, 2009 (see **Attachment 4**).

15. Receiving Stream Water Quality and Water Quality Standards:

a) Ambient Water Quality Data

There is no monitoring data for the unnamed tributary to Mountain Run. The nearest downstream DEQ water quality monitoring station with ambient data is Station 3-MTN000.59, located on Mountain Run at segment VAN-E09R_MTN01A00 at the Rt. 620 bridge crossing, approximately 9.7 miles downstream from the outfall. This segment is listed as not supporting the (1) fish consumption use, (2) aquatic life use and (3) recreational use. The fish consumption use is categorized as impaired due to a Virginia Department of Health, Division of Health Hazards Control, PCB fish consumption advisory. The Aquatic Life Use Impairment is categorized as impaired due to a total of three biological monitoring events in 2003 and 2004 resulted in a VSCI score which indicates an impaired macroinvertebrate community. Sufficient excursions from the instantaneous *E. coli* bacteria criterion (6 of 16 samples - 37.5%) were recorded at DEQ's ambient water quality monitoring station (3-MTN000.59) at the Route 620 crossing to assess this stream segment as not supporting of the recreation use goal for the 2008 water quality assessment (see Planning Statement located in the permit file).

b) Receiving Stream Water Quality Criteria

Part IX of 9 VAC 25-260(360-550) designates classes and special standards applicable to defined Virginia river basins and sections. The receiving stream Mountain Run, UT is located within Section 4 of the Rappahannock River Basin, and classified as a Class III water.

At all times, Class III waters must achieve a dissolved oxygen (D.O.) of 4.0 mg/L or greater, a daily average D.O. of 5.0 mg/L or greater, a temperature that does not exceed 32°C, and maintain a pH of 6.0-9.0 standard units (S.U.).

Attachment 5 details other water quality criteria applicable to the receiving stream.

TKN:

The 7Q10 and 1Q10 of the receiving stream are 0.0 MGD. In cases such as this, effluent pH and temperature data may be used to establish the ammonia water quality standard. The facility, however, has not yet been built. Default pH value of 7.5 S.U., 25ºC, for yearly temperature, and 15 ºC, for high flow temperature, will be used to develop the ammonia criteria. However, it is staff's best professional judgment to propose a TKN limit of 3.0 mg/L since there is no effluent data and the receiving stream is difficult to model. A TKN limit of 3.0 mg/L assumes that the remaining nitrogen is in the form of refractory organic compounds that will not be easily oxidized and that ammonia is removed when this limit is maintained; therefore, a limit for Ammonia as N is not necessary.

Metals Criteria:

The facility has not yet been built, therefore, there is no hardness data available for this facility. Staff guidance suggests using a default hardness value of 50 mg/l $CaCO_3$ for streams east of the Blue Ridge. The hardness-dependent metals criteria in Attachment 5 are based on this value.

Bacteria Criteria: The Virginia Water Quality Standards (9 VAC 25-260-170 B.) states sewage discharges shall be disinfected to achieve the following criteria:

1) *E. coli* bacteria per 100 ml of water shall not exceed the following:

	Geometric Mean[1]	Single Sample Maximum
Freshwater *E. coli* (N/100 ml)	126	235

[1]For two or more samples [taken during any calendar month].

c) Receiving Stream Special Standards

The State Water Control Board's Water Quality Standards, River Basin Section Tables (9VAC25-260-360, 370 and 380) designates the river basins, sections, classes, and special standards for surface waters of the Commonwealth of Virginia. The receiving stream, Mountain Run, UT, is located within Section 4 of the Rappahannock River Basin. This section has no special standard designations.

d) Threatened or Endangered Species

The Virginia DGIF Fish and Wildlife Information System Database was searched for records to determine if there are threatened or endangered species in the vicinity of the discharge. No threatened or endangered species were identified.

16. Antidegradation (9 VAC 25-260-30):

All state surface waters are provided one of three levels of antidegradation protection. For Tier 1 or existing use protection, existing uses of the water body and the water quality to protect these uses must be maintained. Tier 2 water bodies have water quality that is better than the water quality standards. Significant lowering of the water quality of Tier 2 waters is not allowed without an evaluation of the economic and social impacts. Tier 3 water bodies are exceptional waters and are so designated by regulatory amendment. The antidegradation policy prohibits new or expanded discharges into exceptional waters.

The receiving stream has been classified as Tier 1 based on the 7Q10 and 1Q10 of the receiving stream being 0.0 MGD. Permit limits proposed have been established by determining wasteload allocations which will result in attaining and/or maintaining all water quality criteria which apply to the receiving stream, including narrative criteria. These wasteload allocations will provide for the protection and maintenance of all existing uses.

17. Effluent Screening, Wasteload Allocation, and Effluent Limitation Development:

To determine water quality-based effluent limitations for a discharge, the suitability of data must first be determined. Data is suitable for analysis if one or more representative data points is equal to or above the quantification level ("QL") and the data represent the exact pollutant being evaluated.

Next, the appropriate Water Quality Standards (WQS) are determined for the pollutants in the effluent. Then, the Wasteload Allocations (WLA) are calculated. In this case since the critical flows 7Q10 and 1Q10 have been determined to be zero, the WLA's are equal to the WQS. The WLA values are then compared with available effluent data to determine the need for effluent limitations. Effluent limitations are needed if the 97th percentile of the daily effluent concentration values is greater than the acute wasteload allocation or if the 97th percentile of the four-day average effluent concentration values is greater than the chronic wasteload allocation. Effluent limitations are based on the most limiting WLA, the required sampling frequency, and statistical characteristics of the effluent data.

a) Effluent Screening:
This is a proposed discharge; there is no available data to review.

b) Mixing Zones and Wasteload Allocations (WLAs):

Wasteload allocations (WLAs) are calculated for those parameters in the effluent with the reasonable potential to cause an exceedance of water quality criteria. The basic calculation for establishing a WLA is the steady state complete mix equation:

$$WLA = \frac{C_o [Q_e + (f) (Q_s)] - [(C_s) (f) (Q_s)]}{Q_e}$$

Where:
- WLA = Wasteload allocation
- C_o = In-stream water quality criteria
- Q_e = Design flow
- Q_s = Critical receiving stream flow (1Q10 for acute aquatic life criteria; 7Q10 for chronic aquatic life criteria; harmonic mean for carcinogen-human health criteria; 30Q10 for chronic ammonia criteria; and 30Q5 for non-carcinogen human health criteria)
- f = Decimal fraction of critical flow
- C_s = Mean background concentration of parameter in the receiving stream.

The water segment receiving the discharge via Outfall 001 is considered to have a 7Q10 and 1Q10 of 0.0 MGD. As such, there is no mixing zone and the WLA is equal to the C_o.

c) Effluent Limitations Toxic Pollutants, Outfall 001

9 VAC 25-31-220.D. requires limits be imposed where a discharge has a reasonable potential to cause or contribute to an in-stream excursion of water quality criteria. Those parameters with WLAs that are near effluent concentrations are evaluated for limits.

The VPDES Permit Regulation at 9 VAC 25-31-230.D. requires that monthly and weekly average limitations be imposed for continuous discharges from POTWs and monthly average and daily maximum limitations be imposed for all other continuous non-POTW discharges.

1) TKN:

The facility will be given a year round TKN limit of 3.0 mg/L. A TKN limit of 3.0 mg/L assumes that the remaining nitrogen is in the form of refractory organic compounds that will not be easily oxidized and that ammonia is removed when the 3.0 mg/L TKN limit is met. The weekly average limit will be 4.5 mg/L based on a multiplier of 1.5 times the monthly average.

2) Total Residual Chlorine:

Chlorine is not proposed for disinfection; however, the facility does have a swimming pool onsite and plans to discharge the backwash to the WWTP. In accordance with current DEQ guidance, staff used a default data point of 0.2 mg/L and the calculated WLAs to derive limits. A monthly average of 0.008 mg/L and a weekly average limit of 0.010 mg/L are proposed for this discharge (see **Attachment 6**).

3) Metals:

Since this is a proposed wastewater treatment plant, there is no data available to analyze; therefore, no metals limitations are proposed for this issuance.

d) Effluent Limitations and Monitoring, Outfall 001 – Conventional and Non-Conventional Pollutants

Carbonaceous Biochemical Oxygen Demand ($CBOD_5$), Total Suspended Solids (TSS), Dissolved Oxygen (DO), Total Residual Chlorine (TRC) and TKN limitations are based on best professional judgement and Guidance Memo 00-2011. This guidance is applicable to waters such as this portion of Mountain Run, UT where the water is shallow, flow is intermittent, and the waters cannot be modeled.

It is staff's practice to equate the Total Suspended Solids limits with the $CBOD_5$ limits. TSS limits are established to equal $CBOD_5$ limits since the two pollutants are closely related in terms of treatment of domestic sewage.

pH limitations are set at the water quality criteria.

The camp has a swimming pool. As such, chlorine is a pollutant of concern; therefore, TRC limits are established to ensure protection of the receiving stream.

E. coli limitations are in accordance with the Water Quality Standards 9 VAC25-260-170 and the WLA given to the permittee as part of the Mountain Run Watershed Bacteria TMDL modification.

e) Effluent Limitations and Monitoring Summary.

The effluent limitations are presented in the following table. Limits were established for Flow, $CBOD_5$, Total Suspended Solids, TKN, Total Residual Chlorine, pH, *E. coli* and Dissolved Oxygen.

The limit for Total Suspended Solids is based on Best Professional Judgement.

The mass loading (kg/d) for monthly and weekly averages were calculated by multiplying the concentration values (mg/l), with the flow values (in MGD) and a conversion factor of 3.785.

Sample Type and Frequency are in accordance with the recommendations in the VPDES Permit Manual.

The VPDES Permit Regulation at 9 VAC 25-31-30 and 40 CFR Part 133 require that the facility achieve at least 85% removal for CBOD and TSS (or 65% for equivalent to secondary). The limits in this permit are water-quality-based effluent limits and result in greater than 85% removal.

18. Antibacksliding:

Backsliding does not apply since this is an issuance.

19. Effluent Limitations/Monitoring Requirements:

Design flow is 0.0055 MGD.

Effective Dates: During the period beginning with the permit's effective date and lasting until the expiration date.

PARAMETER	BASIS FOR LIMITS	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
		Monthly Average	Weekly Average	Minimum	Maximum	Frequency	Sample Type
Flow (MGD)	NA	NL	NA	NA	NL	1/D	Estimate
pH	3	NA	NA	6.0 S.U.	9.0 S.U.	1/D	Grab
$CBOD_5$	2,3	10 mg/L 0.21 kg/d	15 mg/L 0.31 kg/d	NA	NA	1/M	Grab
Total Suspended Solids (TSS)	2	10 mg/L 0.21 kg/d	15 mg/L 0.31 kg/d	NA	NA	1/M	Grab
DO	3	NA	NA	6.0 mg/L	NA	1/D	Grab
Total Kjeldahl Nitrogen (TKN)	2,3	3.0 mg/L 0.06 kg/d	4.5 mg/L 0.09 kg/d	NA	NA	1/M	Grab
Total Residual Chlorine (TRC)	2,3	0.008 mg/L	0.010 mg/L	NA	NA	1/D	Grab
E. coli (Geometric Mean)	3,4	126 n/100mls	NA	NA	NA	1/W* Between 10am – 4pm	Grab

The basis for the limitations codes are:

1. Federal Effluent Requirements
2. Best Professional Judgement
3. Water Quality Standards
4. Mountain Run TMDL

MGD = Million gallons per day.
NA = Not applicable.
NL = No limit; monitor and report.
S.U. = Standard units.

1/D = Once every day.
1/M = Once every month.
1/W = Once every week, 7 days apart.

Estimate = Reported flow is to be based on the technical evaluation of the sources contributing to the discharge.
Grab = An individual sample collected over a period of time not to exceed 15-minutes.

- If Camp Red Arrow demonstrates full compliance with the *E. coli* effluent limitation after the operation of the first full camp season, the permittee may request in writing, a reduction of the *E. coli* monitoring frequency from once every week to once every week during one month of each calendar quarter that the camp is in operation. Should the permittee be issued a Warning Letter related to violation of the *E. coli* effluent limitation, a Notice of Violation, or be the subject of an active enforcement action, monitoring frequency shall revert to once every week, upon issuance of the letter or notice or initiation of the enforcement action and remain in effect until the permit's expiration date.
- Should the facility discharge during the offseason for any events held onsite, sampling shall be conducted in accordance with the above requirements.

20. Other Permit Requirements :

Part I.B. of the permit contains quantification levels and compliance reporting instructions.

9 VAC 25-31-190.L.4.c. requires an arithmetic mean for measurement averaging and 9 VAC 25-31-220.D. requires limits be imposed where a discharge has a reasonable potential to cause or contribute to an in-stream excursion of water quality criteria. Specific analytical methodologies for toxics are listed in this permit section as well as quantification levels (QLs) necessary to demonstrate compliance with applicable permit limitations or for use in future evaluations to determine if the pollutant has reasonable potential to cause or contribute to a violation. Required averaging methodologies are also specified.

21. Other Special Conditions :

a) 95% Capacity Reopener. The VPDES Permit Regulation at 9 VAC 25-31-200.B.2. requires all POTWs and PVOTWs develop and submit a plan of action to DEQ when the monthly average influent flow to their sewage treatment plant reaches 95% or more of the design capacity authorized in the permit for each month of any three consecutive month period. This facility is a PVOTW.

b) O&M Manual Requirement. Required by Code of Virginia §62.1-44.19; Sewage Collection and Treatment Regulations, 9 VAC 25-790; VPDES Permit Regulation, 9 VAC 25-31-190.E. Within 90 days of completion of construction, the permittee shall submit for approval an Operations and Maintenance (O&M) Manual to the Department of Environmental Quality, Northern Regional Office (DEQ-NRO). Future changes to the facility must be addressed by the submittal of a revised O&M Manual within 90 days of the changes. Non-compliance with the O&M Manual shall be deemed a violation of the permit.

c) CTC, CTO Requirement. The Code of Virginia § 62.1-44.19; Sewage Collection and Treatment Regulations, 9 VAC 25-790 requires that all treatment works treating wastewater obtain a Certificate to Construct prior to commencing construction and to obtain a Certificate to Operate prior to commencing operation of the treatment works.

d) Licensed Operator Requirement. The Code of Virginia at §54.1-2300 et seq. and the VPDES Permit Regulation at 9 VAC 25-31-200 C, and Rules and Regulations for Waterworks and Wastewater Works Operators (18 VAC 160-20-10 et seq.) requires licensure of operators. This facility requires a Class III operator.

e) Reliability Class. The Sewage Collection and Treatment Regulations at 9 VAC 25-790 require sewage treatment works to achieve a certain level of reliability in order to protect water quality and public health consequences in the event of component or system failure. Reliability means a measure of the ability of the treatment works to perform its designated function without failure or interruption of service. The facility is required to meet a reliability Class of II.

f) Water Quality Criteria Reopener. The VPDES Permit Regulation at 9 VAC 25-31-220 D. requires establishment of effluent limitations to ensure attainment/maintenance of receiving stream water quality criteria. Should effluent monitoring indicate the need for any water quality-based limitations, this permit may be modified or alternatively revoked and reissued to incorporate appropriate limitations.

g) Sludge Reopener. The VPDES Permit Regulation at 9 VAC 25-31-200.C.4. requires all permits issued to treatment works treating domestic sewage (including sludge-only facilities) include a reopener clause allowing incorporation of any applicable standard for sewage sludge use or disposal promulgated under Section 405(d) of the CWA. The facility includes a sewage treatment works.

h) Sludge Use and Disposal. The VPDES Permit Regulation at 9 VAC 25-31-100.P., 220.B.2., and 420-720, and 40 CFR Part 503 require all treatment works treating domestic sewage to submit information on their sludge use and disposal practices and to meet specified standards for sludge use and disposal. The facility includes a treatment works treating domestic sewage.

i) Treatment Works Closure Plan. The State Water Control Law §62.1-44.15:1.1, makes it illegal for an owner to cease operation and fail to implement a closure plan when failure to implement the plan would result in harm to human health or the environment. This condition is used to notify the owner of the need for a closure plan where a facility is being replaced or is expected to close.

Permit Section Part II. Part II of the permit contains standard conditions that appear in all VPDES Permits. In general, these standard conditions address the responsibilities of the permittee, reporting requirements, testing procedures and records retention.

22. Changes to the Permit from the Previously Issued Permit:

a) Special Conditions:
None. This is an issuance.
b) Monitoring and Effluent Limitations:
None. This is an issuance.

23. Variances/Alternate Limits or Conditions:
None.

24. Public Notice Information:

First Public Notice Date: December 23, 2009 Second Public Notice Date: December 30, 2009

Public Notice Information is required by 9 VAC 25-31-280 B. All pertinent information is on file and may be inspected, and copied by contacting the: DEQ Northern Regional Office, 13901 Crown Court, Woodbridge, VA 22193, Telephone No. (703) 583-3863, saoakes@deq.virginia.gov. See **Attachment 7** for a copy of the public notice document.

Persons may comment in writing or by email to the DEQ on the proposed permit action, and may request a public hearing, during the comment period. Comments shall include the name, address, and telephone number of the writer, and shall contain a complete, concise statement of the factual basis for comments. Only those comments received within this period will be considered. The DEQ may decide to hold a public hearing if public response is significant. Requests for public hearings shall state the reason why a hearing is requested, the nature of the issues proposed to be raised in the public hearing and a brief explanation of how the requester's interests would be directly and adversely affected by the proposed permit action. Following the comment period, the Board will make a determination regarding the proposed permit action. This determination will become effective, unless the DEQ grants a public hearing. Due notice of any public hearing will be given.

25. 303 (d) Listed Stream Segments and Total Max. Daily Loads (TMDL):
The receiving stream is not on the current 303 (d) list. Mountain Run at segment VAN-E09R_MTN02A04, which begins at the confluence with Jonas Run and continues downstream until the confluence with Flat Run, is, however, listed as not supporting the (1) fish consumption use and (2) aquatic life use. In addition, Mountain Run at segment VAN-E09R_MTN01A00, is listed as not supporting the (1) fish consumption use, (2) aquatic life use and (3) recreational use. This Mountain Run segment begins at the confluence with Flat Run and continues downstream until the confluence with the Rappahannock River. No PCB TMDL (fish consumption use) or Benthic TMDL (aquatic life use) (for both segments), has been prepared but is due in 2018 and 2020 respectively. The Bacteria TMDL (recreational use) was completed and approved by EPA on 4/27/01. Since this is a new facility, no waste load allocation was provided for this facility in the original TMDL. In addition, the Mountain Run Bacteria TMDL was done before it became the practice of DEQ to include a waste load allocation for the future growth and expansion of point sources in the watershed. DEQ modified the TMDL for Mountain Run which includes a specific waste load allocation for this facility. EPA approved the TMDL modification on October 29, 2009. The waste load allocation for this facility is **9.57E+09 cfu/year of *E. coli***. This permit has a limit of 126n/100 ml for *E. coli* which is in compliance with the TMDL.

26. TMDL Reopener: This special condition is to allow the permit to be reopened if necessary to bring it in compliance with any applicable TMDL that may be developed and approved for the receiving stream.

27. Additional Comments:
Previous Board Action(s): Not applicable as this is an issuance.

Staff Comments: Not applicable as this is an issuance.

Public Comment: No comments were received during the public notice.

EPA Checklist: The checklist can be found in **Attachment 8**.

Camp Red Arrow WWTP
Fact Sheet Attachments – Table of Contents
VA0092452

MEMORANDUM

TO: VPDES Permit File – VPDES Permit No. VA0092452

FROM: Susan A. Oakes

SUBJECT: Camp Red Arrow Wastewater Treatment Plant Flow Determination Memo

DATE: March 19, 2009

A VPDES Permit Application was received from Children's Bible Ministries of Virginia, Inc. requesting the issuance of a VPDES permit for a proposed 0.0055 MGD wastewater treatment plant to serve a bible camp for children. The camp expects 100 campers per day with a maximum population of 200 campers per day and a staff of 20.

The proposed discharge point has a drainage area of approximately 0.09 square miles or 60.6 acres. Upstream from the proposed discharge point is an open field. The proposed discharge point is to a dry ditch close to the edge of the property. Due to this observation made during the site visit on February 11, 2009 and the fact that critical flows of drainage areas of less than five (5) square miles are typically zero, all critical flows for the 7Q10 and 1Q10 of the receiving stream (i.e., the dry ditch), have been determined to be 0.0 MGD.


SYSTEM OVERVIEW
DINING HALL
BATH HOUSE BLDG
OFFICE
NURSES STATION
KITCHEN WASTE
NON-KITCHEN WASTE
2,500 GAL GREASE TRAP
5,000 GAL TRASH TANK
EFFLUENT FILTER
2,500 GAL TRASH TANK
3,000 GPD DELTA BIO-POD FIXED FILM TREATMENT UNIT
2,500 GAL TRASH TANK
3,000 GPD DELTABIO-POD FIXED FILM TREATMENT UNIT
5,000 GAL PUMP TANK
5,000 GAL PUMP TANK
SINGLE PASS SAND FILTER
SINGLE PASS SAND FILTER
UV - LIGHTS DISINFECTION
16,000 GAL PUMP TANK
RE-AERATION CHAMBER
SAMPLE CHAMBER
TO STREAM



Attachment 3

February 11, 2009
MEMORANDUM

To: File

From: Susan Oakes, Permit Writer

Subject: Camp Red Arrow WWTP VA0092452, February 11, 2009 Site Visit

---

On February 11, 2009, a DEQ site visit was made to Camp Red Arrow to conduct an inspection for a proposed WWTP permit issuance. Persons present during the inspection were Perry Utz, Director of the Children's Bible Ministries and Alison Thompson and Susan Oakes of DEQ.

Children's Bible Ministries of Virginia, Inc. are proposing to build a 0.0055 mgd sewage treatment plant to serve a bible camp for children. The camp will operate during summer months and several weekends during the year. The current size of the proposed camp is no more than 100 kids with a maximum camp size of 200 campers per day with 20 staff per day.

Mr. Utz provided a walking tour of the campgrounds. The site will have a camp office, check-in building, three cabins, dining hall, nurse's station, bath house, swimming pool and pool pump house. The camp office, bathhouse, dining hall and nurse's station will tie into the proposed wastewater treatment system. The proposed system will consist of a dual train treatment system. A 2,500 gallon grease trap tank (trash tank) will be provided for the kitchen waste coming from the dining hall and enter a 5,000 gallon septic tank. All non-kitchen waste will bypass the grease trap tank and tie in to the line entering the 5,000 gallon septic tank (trash tank). This tank is for solids and primary settling. Wastewater will then split and flow to two 2,500 gallon trash tanks followed by two 3,000 gpd Fixed Film Delta Treatment units which are proposed to provide 90% reduction in BOD and TSS. The wastewater will then be dosed via two 5,000 gallon pump tanks to two single pass sand filters on to two UV disinfection units followed by a 16,000 gallon discharge pump tank. The treated and disinfected effluent will then enter a 500 gallon re-aeration chamber in 114.5 gallon doses every 30 minutes. It is then pumped to the discharge ditch where it will make its way to Mountain Run.

The WWTP location will be in the northwest corner of the property. Effluent will gravity flow southeasterly from the WWTP past the swimming pool through a field along the edge of an old lagoon where it will turn north again to discharge into a ditch at the edge of the property. It is noted that the discharge for the backwash from the pool pump house will need to be addressed by either tying into the WWTP discharge or establishing its' own outfall. In addition, the lagoon will need to be closed in accordance with the SCAT regulations.

General Location of Proposed WWTP

Abandoned Sewage Disposal Pond

Discharge Ditch

Pool Pump House

FRESHWATER
WATER QUALITY CRITERIA / WASTELOAD ALLOCATION ANALYSIS

Facility Name: Camp Red Arrow WWTP Permit No.: VA0092452

Receiving Stream: Mountain Run, UT Version: OWP Guidance Memo 00-2011 (8/24/00)

Stream Information			Stream Flows			Mixing Information			Effluent Information		
Mean Hardness (as CaCO3) =		mg/L	1Q10 (Annual) =	0	MGD	Annual - 1Q10 Mix =	0	%	Mean Hardness (as CaCO3) =	50	mg/L
90% Temperature (Annual) =		deg C	7Q10 (Annual) =	0	MGD	- 7Q10 Mix =	0	%	90% Temp (Annual) =	25	deg C
90% Temperature (Wet season) =		deg C	30Q10 (Annual) =	0	MGD	- 30Q10 Mix =	0	%	90% Temp (Wet season) =	15	deg C
90% Maximum pH =		SU	1Q10 (Wet season) =	0	MGD	Wet Season - 1Q10 Mix =	0	%	90% Maximum pH =	7.5	SU
10% Maximum pH =		SU	30Q10 (Wet season)	0	MGD	- 30Q10 Mix =	0	%	10% Maximum pH =		SU
Tier Designation (1 or 2) =	1		30Q5 =	0	MGD				Discharge Flow =	0.0055	MGD
Public Water Supply (PWS) Y/N? =	n		Harmonic Mean =	0	MGD						
Trout Present Y/N? =	n										
Early Life Stages Present Y/N? =	y										

Parameter	Background	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				**Most Limiting Allocations**			
(ug/l unless noted)	Conc.	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	**Acute**	**Chronic**	**HH (PWS)**	**HH**
Acenapthene	0	--	--	na	9.9E+02	--	--	na	9.9E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**9.9E+02**
Acrolein	0	--	--	na	9.3E+00	--	--	na	9.3E+00	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**9.3E+00**
Acrylonitrile[C]	0	--	--	na	2.5E+00	--	--	na	2.5E+00	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.5E+00**
Aldrin [C]	0	3.0E+00	--	na	5.0E-04	3.0E+00	--	na	5.0E-04	--	--	--	--	--	--	--	--	**3.0E+00**	**--**	**na**	**5.0E-04**
Ammonia-N (mg/l) (Yearly)	0	1.99E+01	2.22E+00	na	--	2.0E+01	2.2E+00	na	--	--	--	--	--	--	--	--	--	**2.0E+01**	**2.2E+00**	**na**	**--**
Ammonia-N (mg/l) (High Flow)	0	1.99E+01	4.23E+00	na	--	2.0E+01	4.2E+00	na	--	--	--	--	--	--	--	--	--	**2.0E+01**	**4.2E+00**	**na**	**--**
Anthracene	0	--	--	na	4.0E+04	--	--	na	4.0E+04	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**4.0E+04**
Antimony	0	--	--	na	6.4E+02	--	--	na	6.4E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**6.4E+02**
Arsenic	0	3.4E+02	1.5E+02	na	--	3.4E+02	1.5E+02	na	--	--	--	--	--	--	--	--	--	**3.4E+02**	**1.5E+02**	**na**	**--**
Barium	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Benzene [C]	0	--	--	na	5.1E+02	--	--	na	5.1E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**5.1E+02**
Benzidine[C]	0	--	--	na	2.0E-03	--	--	na	2.0E-03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.0E-03**
Benzo (a) anthracene [C]	0	--	--	na	1.8E-01	--	--	na	1.8E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.8E-01**
Benzo (b) fluoranthene [C]	0	--	--	na	1.8E-01	--	--	na	1.8E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.8E-01**
Benzo (k) fluoranthene [C]	0	--	--	na	1.8E-01	--	--	na	1.8E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.8E-01**
Benzo (a) pyrene [C]	0	--	--	na	1.8E-01	--	--	na	1.8E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.8E-01**
Bis2-Chloroethyl Ether[C]	0	--	--	na	5.3E+00	--	--	na	5.3E+00	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**5.3E+00**
Bis2-Chloroisopropyl Ether	0	--	--	na	6.5E+04	--	--	na	6.5E+04	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**6.5E+04**
Bis 2-Ethylhexyl Phthalate[C]	0	--	--	na	2.2E+01	--	--	na	2.2E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.2E+01**
Bromoform [C]	0	--	--	na	1.4E+03	--	--	na	1.4E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.4E+03**
Butylbenzylphthalate	0	--	--	na	1.9E+03	--	--	na	1.9E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.9E+03**
Cadmium	0	1.8E+00	6.6E-01	na	--	1.8E+00	6.6E-01	na	--	--	--	--	--	--	--	--	--	**1.8E+00**	**6.6E-01**	**na**	**--**
Carbon Tetrachloride [C]	0	--	--	na	1.6E+01	--	--	na	1.6E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.6E+01**
Chlordane [C]	0	2.4E+00	4.3E-03	na	8.1E-03	2.4E+00	4.3E-03	na	8.1E-03	--	--	--	--	--	--	--	--	**2.4E+00**	**4.3E-03**	**na**	**8.1E-03**
Chloride	0	8.6E+05	2.3E+05	na	--	8.6E+05	2.3E+05	na	--	--	--	--	--	--	--	--	--	**8.6E+05**	**2.3E+05**	**na**	**--**
TRC	0	1.9E+01	1.1E+01	na	--	1.9E+01	1.1E+01	na	--	--	--	--	--	--	--	--	--	**1.9E+01**	**1.1E+01**	**na**	**--**
Chlorobenzene	0	--	--	na	1.6E+03	--	--	na	1.6E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.6E+03**

Parameter	Background	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				**Most Limiting Allocations**			
(ug/l unless noted)	Conc.	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	**Acute**	**Chronic**	**HH (PWS)**	**HH**
Chlorodibromomethane[C]	0	--	--	na	1.3E+02	--	--	na	1.3E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.3E+02**
Chloroform	0	--	--	na	1.1E+04	--	--	na	1.1E+04	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.1E+04**
2-Chloronaphthalene	0	--	--	na	1.6E+03	--	--	na	1.6E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.6E+03**
2-Chlorophenol	0	--	--	na	1.5E+02	--	--	na	1.5E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.5E+02**
Chlorpyrifos	0	8.3E-02	4.1E-02	na	--	8.3E-02	4.1E-02	na	--	--	--	--	--	--	--	--	--	**8.3E-02**	**4.1E-02**	**na**	**--**
Chromium III	0	3.2E+02	4.2E+01	na	--	3.2E+02	4.2E+01	na	--	--	--	--	--	--	--	--	--	**3.2E+02**	**4.2E+01**	**na**	**--**
Chromium VI	0	1.6E+01	1.1E+01	na	--	1.6E+01	1.1E+01	na	--	--	--	--	--	--	--	--	--	**1.6E+01**	**1.1E+01**	**na**	**--**
Chromium, Total	0	--	--	1.0E+02	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Chrysene [C]	0	--	--	na	1.8E-02	--	--	na	1.8E-02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.8E-02**
Copper	0	7.0E+00	5.0E+00	na	--	7.0E+00	5.0E+00	na	--	--	--	--	--	--	--	--	--	**7.0E+00**	**5.0E+00**	**na**	**--**
Cyanide, Free	0	2.2E+01	5.2E+00	na	1.6E+04	2.2E+01	5.2E+00	na	1.6E+04	--	--	--	--	--	--	--	--	**2.2E+01**	**5.2E+00**	**na**	**1.6E+04**
DDD [C]	0	--	--	na	3.1E-03	--	--	na	3.1E-03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**3.1E-03**
DDE [C]	0	--	--	na	2.2E-03	--	--	na	2.2E-03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.2E-03**
DDT [C]	0	1.1E+00	1.0E-03	na	2.2E-03	1.1E+00	1.0E-03	na	2.2E-03	--	--	--	--	--	--	--	--	**1.1E+00**	**1.0E-03**	**na**	**2.2E-03**
Demeton	0	--	1.0E-01	na	--	--	1.0E-01	na	--	--	--	--	--	--	--	--	--	**--**	**1.0E-01**	**na**	**--**
Diazinon	0	1.7E-01	1.7E-01	na	--	1.7E-01	1.7E-01	na	--	--	--	--	--	--	--	--	--	**1.7E-01**	**1.7E-01**	**na**	**--**
Dibenz(a,h)anthracene [C]	0	--	--	na	1.8E-01	--	--	na	1.8E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.8E-01**
1,2-Dichlorobenzene	0	--	--	na	1.3E+03	--	--	na	1.3E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.3E+03**
1,3-Dichlorobenzene	0	--	--	na	9.6E+02	--	--	na	9.6E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**9.6E+02**
1,4-Dichlorobenzene	0	--	--	na	1.9E+02	--	--	na	1.9E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.9E+02**
3,3-Dichlorobenzidine[C]	0	--	--	na	2.8E-01	--	--	na	2.8E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.8E-01**
Dichlorobromomethane [C]	0	--	--	na	1.7E+02	--	--	na	1.7E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.7E+02**
1,2-Dichloroethane [C]	0	--	--	na	3.7E+02	--	--	na	3.7E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**3.7E+02**
1,1-Dichloroethylene	0	--	--	na	7.1E+03	--	--	na	7.1E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**7.1E+03**
1,2-trans-dichloroethylene	0	--	--	na	1.0E+04	--	--	na	1.0E+04	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.0E+04**
2,4-Dichlorophenol	0	--	--	na	2.9E+02	--	--	na	2.9E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.9E+02**
2,4-Dichlorophenoxy acetic acid (2,4-D)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
1,2-Dichloropropane[C]	0	--	--	na	1.5E+02	--	--	na	1.5E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.5E+02**
1,3-Dichloropropene [C]	0	--	--	na	2.1E+02	--	--	na	2.1E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.1E+02**
Dieldrin [C]	0	2.4E-01	5.6E-02	na	5.4E-04	2.4E-01	5.6E-02	na	5.4E-04	--	--	--	--	--	--	--	--	**2.4E-01**	**5.6E-02**	**na**	**5.4E-04**
Diethyl Phthalate	0	--	--	na	4.4E+04	--	--	na	4.4E+04	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**4.4E+04**
2,4-Dimethylphenol	0	--	--	na	8.5E+02	--	--	na	8.5E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**8.5E+02**
Dimethyl Phthalate	0	--	--	na	1.1E+06	--	--	na	1.1E+06	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.1E+06**
Di-n-Butyl Phthalate	0	--	--	na	4.5E+03	--	--	na	4.5E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**4.5E+03**
2,4 Dinitrophenol	0	--	--	na	5.3E+03	--	--	na	5.3E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**5.3E+03**
2-Methyl-4,6-Dinitrophenol	0	--	--	na	2.8E+02	--	--	na	2.8E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.8E+02**
2,4-Dinitrotoluene [C]	0	--	--	na	3.4E+01	--	--	na	3.4E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**3.4E+01**
Dioxin 2,3,7,8-tetrachlorodibenzo-p-dioxin	0	--	--	na	5.1E-08	--	--	na	5.1E-08	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**5.1E-08**
1,2-Diphenylhydrazine[C]	0	--	--	na	2.0E+00	--	--	na	2.0E+00	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.0E+00**
Alpha-Endosulfan	0	2.2E-01	5.6E-02	na	8.9E+01	2.2E-01	5.6E-02	na	8.9E+01	--	--	--	--	--	--	--	--	**2.2E-01**	**5.6E-02**	**na**	**8.9E+01**
Beta-Endosulfan	0	2.2E-01	5.6E-02	na	8.9E+01	2.2E-01	5.6E-02	na	8.9E+01	--	--	--	--	--	--	--	--	**2.2E-01**	**5.6E-02**	**na**	**8.9E+01**
Alpha + Beta Endosulfan	0	2.2E-01	5.6E-02	--	--	2.2E-01	5.6E-02	--	--	--	--	--	--	--	--	--	--	**2.2E-01**	**5.6E-02**	**--**	**--**
Endosulfan Sulfate	0	--	--	na	8.9E+01	--	--	na	8.9E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**8.9E+01**
Endrin	0	8.6E-02	3.6E-02	na	6.0E-02	8.6E-02	3.6E-02	na	6.0E-02	--	--	--	--	--	--	--	--	**8.6E-02**	**3.6E-02**	**na**	**6.0E-02**
Endrin Aldehyde	0	--	--	na	3.0E-01	--	--	na	3.0E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**3.0E-01**

Parameter	Background	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				**Most Limiting Allocations**			
(ug/l unless noted)	Conc.	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	**Acute**	**Chronic**	**HH (PWS)**	**HH**
Ethylbenzene	0	--	--	na	2.1E+03	--	--	na	2.1E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.1E+03**
Fluoranthene	0	--	--	na	1.4E+02	--	--	na	1.4E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.4E+02**
Fluorene	0	--	--	na	5.3E+03	--	--	na	5.3E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**5.3E+03**
Foaming Agents	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Guthion	0	--	1.0E-02	na	--	--	1.0E-02	na	--	--	--	--	--	--	--	--	--	**--**	**1.0E-02**	**na**	**--**
Heptachlor [C]	0	5.2E-01	3.8E-03	na	7.9E-04	5.2E-01	3.8E-03	na	7.9E-04	--	--	--	--	--	--	--	--	**5.2E-01**	**3.8E-03**	**na**	**7.9E-04**
Heptachlor Epoxide[C]	0	5.2E-01	3.8E-03	na	3.9E-04	5.2E-01	3.8E-03	na	3.9E-04	--	--	--	--	--	--	--	--	**5.2E-01**	**3.8E-03**	**na**	**3.9E-04**
Hexachlorobenzene[C]	0	--	--	na	2.9E-03	--	--	na	2.9E-03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.9E-03**
Hexachlorobutadiene[C]	0	--	--	na	1.8E+02	--	--	na	1.8E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.8E+02**
Hexachlorocyclohexane Alpha-BHC[C]	0	--	--	na	4.9E-02	--	--	na	4.9E-02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**4.9E-02**
Hexachlorocyclohexane Beta-BHC[C]	0	--	--	na	1.7E-01	--	--	na	1.7E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.7E-01**
Hexachlorocyclohexane Gamma-BHC[C] (Lindane)	0	9.5E-01	na	na	1.8E+00	9.5E-01	--	na	1.8E+00	--	--	--	--	--	--	--	--	**9.5E-01**	**--**	**na**	**1.8E+00**
Hexachlorocyclopentadiene	0	--	--	na	1.1E+03	--	--	na	1.1E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.1E+03**
Hexachloroethane[C]	0	--	--	na	3.3E+01	--	--	na	3.3E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**3.3E+01**
Hydrogen Sulfide	0	--	2.0E+00	na	--	--	2.0E+00	na	--	--	--	--	--	--	--	--	--	**--**	**2.0E+00**	**na**	**--**
Indeno (1,2,3-cd) pyrene [C]	0	--	--	na	1.8E-01	--	--	na	1.8E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.8E-01**
Iron	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Isophorone[C]	0	--	--	na	9.6E+03	--	--	na	9.6E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**9.6E+03**
Kepone	0	--	0.0E+00	na	--	--	0.0E+00	na	--	--	--	--	--	--	--	--	--	**--**	**0.0E+00**	**na**	**--**
Lead	0	4.9E+01	5.6E+00	na	--	4.9E+01	5.6E+00	na	--	--	--	--	--	--	--	--	--	**4.9E+01**	**5.6E+00**	**na**	**--**
Malathion	0	--	1.0E-01	na	--	--	1.0E-01	na	--	--	--	--	--	--	--	--	--	**--**	**1.0E-01**	**na**	**--**
Manganese	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Mercury	0	1.4E+00	7.7E-01	- -	- -	1.4E+00	7.7E-01	- -	- -	--	--	--	--	--	--	--	--	**1.4E+00**	**7.7E-01**	**- -**	**- -**
Methyl Bromide	0	--	--	na	1.5E+03	--	--	na	1.5E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.5E+03**
Methylene Chloride [C]	0	--	--	na	5.9E+03	--	--	na	5.9E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**5.9E+03**
Methoxychlor	0	--	3.0E-02	na	--	--	3.0E-02	na	--	--	--	--	--	--	--	--	--	**--**	**3.0E-02**	**na**	**--**
Mirex	0	--	0.0E+00	na	--	--	0.0E+00	na	--	--	--	--	--	--	--	--	--	**--**	**0.0E+00**	**na**	**--**
Nickel	0	1.0E+02	1.1E+01	na	4.6E+03	1.0E+02	1.1E+01	na	4.6E+03	--	--	--	--	--	--	--	--	**1.0E+02**	**1.1E+01**	**na**	**4.6E+03**
Nitrate (as N)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Nitrobenzene	0	--	--	na	6.9E+02	--	--	na	6.9E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**6.9E+02**
N-Nitrosodimethylamine[C]	0	--	--	na	3.0E+01	--	--	na	3.0E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**3.0E+01**
N-Nitrosodiphenylamine[C]	0	--	--	na	6.0E+01	--	--	na	6.0E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**6.0E+01**
N-Nitrosodi-n-propylamine[C]	0	--	--	na	5.1E+00	--	--	na	5.1E+00	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**5.1E+00**
Nonylphenol	0	2.8E+01	6.6E+00	--	--	2.8E+01	6.6E+00	na	--	--	--	--	--	--	--	--	--	**2.8E+01**	**6.6E+00**	**na**	**--**
Parathion	0	6.5E-02	1.3E-02	na	--	6.5E-02	1.3E-02	na	--	--	--	--	--	--	--	--	--	**6.5E-02**	**1.3E-02**	**na**	**--**
PCB Total[C]	0	--	1.4E-02	na	6.4E-04	--	1.4E-02	na	6.4E-04	--	--	--	--	--	--	--	--	**--**	**1.4E-02**	**na**	**6.4E-04**
Pentachlorophenol [C]	0	7.7E-03	5.9E-03	na	3.0E+01	7.7E-03	5.9E-03	na	3.0E+01	--	--	--	--	--	--	--	--	**7.7E-03**	**5.9E-03**	**na**	**3.0E+01**
Phenol	0	--	--	na	8.6E+05	--	--	na	8.6E+05	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**8.6E+05**
Pyrene	0	--	--	na	4.0E+03	--	--	na	4.0E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**4.0E+03**
Radionuclides	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Gross Alpha Activity (pCi/L)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Beta and Photon Activity (mrem/yr)	0	--	--	na	4.0E+00	--	--	na	4.0E+00	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**4.0E+00**
Radium 226 + 228 (pCi/L)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Uranium (ug/l)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**

Parameter	Background	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				**Most Limiting Allocations**			
(ug/l unless noted)	Conc.	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	**Acute**	**Chronic**	**HH (PWS)**	**HH**
Selenium, Total Recoverable	0	2.0E+01	5.0E+00	na	4.2E+03	2.0E+01	5.0E+00	na	4.2E+03	--	--	--	--	--	--	--	--	**2.0E+01**	**5.0E+00**	**na**	**4.2E+03**
Silver	0	1.0E+00	--	na	--	1.0E+00	--	na	--	--	--	--	--	--	--	--	--	**1.0E+00**	**--**	**na**	**--**
Sulfate	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
1,1,2,2-Tetrachloroethane[C]	0	--	--	na	4.0E+01	--	--	na	4.0E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**4.0E+01**
Tetrachloroethylene[C]	0	--	--	na	3.3E+01	--	--	na	3.3E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**3.3E+01**
Thallium	0	--	--	na	4.7E-01	--	--	na	4.7E-01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**4.7E-01**
Toluene	0	--	--	na	6.0E+03	--	--	na	6.0E+03	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**6.0E+03**
Total dissolved solids	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Toxaphene [C]	0	7.3E-01	2.0E-04	na	2.8E-03	7.3E-01	2.0E-04	na	2.8E-03	--	--	--	--	--	--	--	--	**7.3E-01**	**2.0E-04**	**na**	**2.8E-03**
Tributyltin	0	4.6E-01	7.2E-02	na	--	4.6E-01	7.2E-02	na	--	--	--	--	--	--	--	--	--	**4.6E-01**	**7.2E-02**	**na**	**--**
1,2,4-Trichlorobenzene	0	--	--	na	7.0E+01	--	--	na	7.0E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**7.0E+01**
1,1,2-Trichloroethane[C]	0	--	--	na	1.6E+02	--	--	na	1.6E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**1.6E+02**
Trichloroethylene [C]	0	--	--	na	3.0E+02	--	--	na	3.0E+02	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**3.0E+02**
2,4,6-Trichlorophenol [C]	0	--	--	na	2.4E+01	--	--	na	2.4E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.4E+01**
2-(2,4,5-Trichlorophenoxy) propionic acid (Silvex)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**--**
Vinyl Chloride[C]	0	--	--	na	2.4E+01	--	--	na	2.4E+01	--	--	--	--	--	--	--	--	**--**	**--**	**na**	**2.4E+01**
Zinc	0	6.5E+01	6.6E+01	na	2.6E+04	6.5E+01	6.6E+01	na	2.6E+04	--	--	--	--	--	--	--	--	**6.5E+01**	**6.6E+01**	**na**	**2.6E+04**

Notes:

1. All concentrations expressed as micrograms/liter (ug/l), unless noted otherwise
2. Discharge flow is highest monthly average or Form 2C maximum for Industries and design flow for Municipals
3. Metals measured as Dissolved, unless specified otherwise
4. "C" indicates a carcinogenic parameter
5. Regular WLAs are mass balances (minus background concentration) using the % of stream flow entered above under Mixing Information.
   Antidegradation WLAs are based upon a complete mix.
6. Antideg. Baseline = (0.25(WQC - background conc.) + background conc.) for acute and chronic
   = (0.1(WQC - background conc.) + background conc.) for human health
7. WLAs established at the following stream flows: 1Q10 for Acute, 30Q10 for Chronic Ammonia, 7Q10 for Other Chronic, 30Q5 for Non-carcinogens and Harmonic Mean for Carcinogens. To apply mixing ratios from a model set the stream flow equal to (mixing ratio - 1), effluent flow equal to 1 and 100% mix.

Metal	Target Value (SSTV)
Antimony	6.4E+02
Arsenic	9.0E+01
Barium	na
Cadmium	3.9E-01
Chromium III	2.5E+01
Chromium VI	6.4E+00
Copper	2.8E+00
Iron	na
Lead	3.4E+00
Manganese	na
Mercury	4.6E-01
Nickel	6.8E+00
Selenium	3.0E+00
Silver	4.2E-01
Zinc	2.6E+01

Note: do not use QL's lower than the minimum QL's provided in agency guidance

3/30/2009 9:30:15 AM

Facility = Camp Red Arrow
Chemical = TRC
Chronic averaging period = 4
WLAa = 0.019
WLAc = 0.011
Q.L. = 0.1
# samples/mo. = 30
# samples/wk. = 8

Summary of Statistics:

observations = 1
Expected Value = .2
Variance = .0144
C.V. = 0.6
97th percentile daily values = .486683
97th percentile 4 day average = .332758
97th percentile 30 day average= .241210
< Q.L. = 0
Model used = BPJ Assumptions, type 2 data

A limit is needed based on Chronic Toxicity
Maximum Daily Limit = 1.60883226245855E-02
Average Weekly limit = 9.59676626920106E-03
Average Monthly LImit = 7.9737131838758E-03

The data are:

0.2

Public Notice – Environmental Permit

PURPOSE OF NOTICE: To seek public comment on a draft permit from the Department of Environmental Quality that will allow the release of treated wastewater into a water body in Culpeper/Culpeper County, Virginia.

PUBLIC COMMENT PERIOD: December XX, 2009 to 5:00 p.m. on January XX, 2010

PERMIT NAME: Virginia Pollutant Discharge Elimination System Permit – Wastewater issued by DEQ, under the authority of the State Water Control Board

APPLICANT NAME, ADDRESS AND PERMIT NUMBER: Children's Bible Ministries of Virginia, Inc.
578 Covered Bridge Drive, Madison, VA 22727
VA0092452

NAME AND ADDRESS OF FACILITY: Camp Red Arrow WWTP
19262 Mulford Camp Road, Culpeper, VA 22701

PROJECT DESCRIPTION: Children's Bible Ministries of Virginia, Inc. has applied for a new permit for the private Camp Red Arrow. The applicant proposes to release treated sewage wastewaters from a children's bible camp at a rate of 0.0055 million gallons per day into a water body. The sludge from the treatment process will be transported offsite by a licensed waste hauler to a treatment facility for final treatment and disposal. The facility proposes to release the treated sewage in the Mountain Run, UT in Culpeper/Culpeper County in the Rappahannock watershed. A watershed is the land area drained by a river and its incoming streams. The permit will limit the following pollutants to amounts that protect water quality: pH, $cBOD_5$, Total Suspended Solids, Dissolved Oxygen, Total Kjeldahl Nitrogen, Total Residual Chlorine and *E. coli*.

HOW TO COMMENT AND/OR REQUEST A PUBLIC HEARING: DEQ accepts comments and requests for public hearing by e-mail, fax or postal mail. All comments and requests must be in writing and be received by DEQ during the comment period. Submittals must include the names, mailing addresses and telephone numbers of the commenter/requester and of all persons represented by the commenter/requester. A request for public hearing must also include: 1) The reason why a public hearing is requested. 2) A brief, informal statement regarding the nature and extent of the interest of the requester or of those represented by the requestor, including how and to what extent such interest would be directly and adversely affected by the permit. 3) Specific references, where possible, to terms and conditions of the permit with suggested revisions. DEQ may hold a public hearing, including another comment period, if public response is significant and there are substantial, disputed issues relevant to the permit.

CONTACT FOR PUBLIC COMMENTS, DOCUMENT REQUESTS AND ADDITIONAL INFORMATION: The public may review the documents at the DEQ-Northern Regional Office by appointment, or may request electronic copies of the draft permit and fact sheet.
Name: Susan Oakes
Address: DEQ-Northern Regional Office, 13901 Crown Court, Woodbridge, VA 22193
Phone: (703) 583-3863 E-mail: susan.oakes@deq.virginia.gov Fax: (703) 583-3821

Revised 2/2003

State "Transmittal Checklist" to Assist in Targeting
Municipal and Industrial Individual NPDES Draft Permits for Review

Part I. State Draft Permit Submission Checklist

In accordance with the MOA established between the Commonwealth of Virginia and the United States Environmental Protection Agency, Region III, the Commonwealth submits the following draft National Pollutant Discharge Elimination System (NPDES) permit for Agency review and concurrence.

Facility Name:	Camp Red Arrow WWTP
NPDES Permit Number:	VA0092452
Permit Writer Name:	Susan Oakes
Date:	March 23, 2009

Major [ ] **Minor** [X] **Industrial** [ ] **Municipal** [X]

I.A. Draft Permit Package Submittal Includes:	**Yes**	**No**	**N/A**
1. Permit Application?	X		
2. Complete Draft Permit (for renewal or first time permit – entire permit, including boilerplate information)?	X		
3. Copy of Public Notice?	X		
4. Complete Fact Sheet?	X		
5. A Priority Pollutant Screening to determine parameters of concern?			X
6. A Reasonable Potential analysis showing calculated WQBELs?	X		
7. Dissolved Oxygen calculations?			X
8. Whole Effluent Toxicity Test summary and analysis?			X
9. Permit Rating Sheet for new or modified industrial facilities?			X

I.B. Permit/Facility Characteristics	**Yes**	**No**	**N/A**
1. Is this a new, or currently unpermitted facility?	X		
2. Are all permissible outfalls (including combined sewer overflow points, non-process water and storm water) from the facility properly identified and authorized in the permit?	X		
3. Does the fact sheet **or** permit contain a description of the wastewater treatment process?	X		
4. Does the review of PCS/DMR data for at least the last 3 years indicate significant non-compliance with the existing permit?			X
5. Has there been any change in streamflow characteristics since the last permit was developed?			X
6. Does the permit allow the discharge of new or increased loadings of any pollutants?			X
7. Does the fact sheet **or** permit provide a description of the receiving water body(s) to which the facility discharges, including information on low/critical flow conditions and designated/existing uses?	X		
8. Does the facility discharge to a 303(d) listed water?		X	
a. Has a TMDL been developed and approved by EPA for the impaired water?	X		
b. Does the record indicate that the TMDL development is on the State priority list and will most likely be developed within the life of the permit?	X		
c. Does the facility discharge a pollutant of concern identified in the TMDL or 303(d) listed water?	X		

9. Have any limits been removed, or are any limits less stringent, than those in the current permit?			X
10. Does the permit authorize discharges of storm water?		X	
I.B. Permit/Facility Characteristics – cont.	**Yes**	**No**	**N/A**
11. Has the facility substantially enlarged or altered its operation or substantially increased its flow or production?			X
12. Are there any production-based, technology-based effluent limits in the permit?		X	
13. Do any water quality-based effluent limit calculations differ from the State's standard policies or procedures?		X	
14. Are any WQBELs based on an interpretation of narrative criteria?		X	
15. Does the permit incorporate any variances or other exceptions to the State's standards or regulations?		X	
16. Does the permit contain a compliance schedule for any limit or condition?		X	
17. Is there a potential impact to endangered/threatened species or their habitat by the facility's discharge(s)?		X	
18. Have impacts from the discharge(s) at downstream potable water supplies been evaluated?	X		
19. Is there any indication that there is significant public interest in the permit action proposed for this facility?		X	
20. Have previous permit, application, and fact sheet been examined?			X

Part II. NPDES Draft Permit Checklist

Region III NPDES Permit Quality Checklist – for POTWs
(To be completed and included in the record only for POTWs)

II.A. Permit Cover Page/Administration	**Yes**	**No**	**N/A**
1. Does the fact sheet or permit describe the physical location of the facility, including latitude and longitude (not necessarily on permit cover page)?	X		
2. Does the permit contain specific authorization-to-discharge information (from where to where, by whom)?	X		

II.B. Effluent Limits – General Elements	**Yes**	**No**	**N/A**
1. Does the fact sheet describe the basis of final limits in the permit (e.g., that a comparison of technology and water quality-based limits was performed, and the most stringent limit selected)?	X		
2. Does the fact sheet discuss whether "antibacksliding" provisions were met for any limits that are less stringent than those in the previous NPDES permit?			X

II.C. Technology-Based Effluent Limits (POTWs)	**Yes**	**No**	**N/A**
1. Does the permit contain numeric limits for ALL of the following: BOD (or alternative, e.g., CBOD, COD, TOC), TSS, and pH?	X		
2. Does the permit require at least 85% removal for BOD (or BOD alternative) and TSS (or 65% for equivalent to secondary) consistent with 40 CFR Part 133?	X		
a. If no, does the record indicate that application of WQBELs, or some other means, results in more stringent requirements than 85% removal or that an exception consistent with 40 CFR 133.103 has been approved?			X
3. Are technology-based permit limits expressed in the appropriate units of measure (e.g., concentration, mass, SU)?	X		
4. Are permit limits for BOD and TSS expressed in terms of both long term (e.g., average monthly) and short term (e.g., average weekly) limits?	X		
5. Are any concentration limitations in the permit less stringent than the secondary treatment requirements (30 mg/l BOD5 and TSS for a 30-day average and 45 mg/l BOD5 and TSS for a 7-day average)?		X	
a. If yes, does the record provide a justification (e.g., waste stabilization pond, trickling filter, etc.) for the alternate limitations?			X

II.D. Water Quality-Based Effluent Limits	**Yes**	**No**	**N/A**
1. Does the permit include appropriate limitations consistent with 40 CFR 122.44(d) covering State narrative and numeric criteria for water quality?	X		
2. Does the fact sheet indicate that any WQBELs were derived from a completed and EPA approved TMDL?	X		
3. Does the fact sheet provide effluent characteristics for each outfall?	X		
4. Does the fact sheet document that a "reasonable potential" evaluation was performed?	X		
a. If yes, does the fact sheet indicate that the "reasonable potential" evaluation was performed in accordance with the State's approved procedures?	X		
b. Does the fact sheet describe the basis for allowing or disallowing in-stream dilution or a mixing zone?		X	
c. Does the fact sheet present WLA calculation procedures for all pollutants that were found to have "reasonable potential"?	X		
d. Does the fact sheet indicate that the "reasonable potential" and WLA calculations accounted for contributions from upstream sources (i.e., do calculations include ambient/background concentrations)?			X
e. Does the permit contain numeric effluent limits for all pollutants for which "reasonable potential" was determined?	X		
II.D. Water Quality-Based Effluent Limits – cont.	**Yes**	**No**	**N/A**

5. Are all final WQBELs in the permit consistent with the justification and/or documentation provided in the fact sheet?	X		
6. For all final WQBELs, are BOTH long-term AND short-term effluent limits established?	X		
7. Are WQBELs expressed in the permit using appropriate units of measure (e.g., mass, concentration)?	X		
8. Does the record indicate that an "antidegradation" review was performed in accordance with the State's approved antidegradation policy?			X

II.E. Monitoring and Reporting Requirements	**Yes**	**No**	**N/A**
1. Does the permit require at least annual monitoring for all limited parameters and other monitoring as required by State and Federal regulations?	X		
a. If no, does the fact sheet indicate that the facility applied for and was granted a monitoring waiver, AND, does the permit specifically incorporate this waiver?			
2. Does the permit identify the physical location where monitoring is to be performed for each outfall?	X		
3. Does the permit require at least annual influent monitoring for BOD (or BOD alternative) and TSS to assess compliance with applicable percent removal requirements?		X	
4. Does the permit require testing for Whole Effluent Toxicity?		X	

II.F. Special Conditions	**Yes**	**No**	**N/A**
1. Does the permit include appropriate biosolids use/disposal requirements?	X		
2. Does the permit include appropriate storm water program requirements?			X

II.F. Special Conditions – cont.	**Yes**	**No**	**N/A**
3. If the permit contains compliance schedule(s), are they consistent with statutory and regulatory deadlines and requirements?			X
4. Are other special conditions (e.g., ambient sampling, mixing studies, TIE/TRE, BMPs, special studies) consistent with CWA and NPDES regulations?	X		
5. Does the permit allow/authorize discharge of sanitary sewage from points other than the POTW outfall(s) or CSO outfalls [i.e., Sanitary Sewer Overflows (SSOs) or treatment plant bypasses]?			X
6. Does the permit authorize discharges from Combined Sewer Overflows (CSOs)?			X
a. Does the permit require implementation of the "Nine Minimum Controls"?			X
b. Does the permit require development and implementation of a "Long Term Control Plan"?			X
c. Does the permit require monitoring and reporting for CSO events?			X
7. Does the permit include appropriate Pretreatment Program requirements?			X

II.G. Standard Conditions	**Yes**	**No**	**N/A**
1. Does the **permit** contain all 40 CFR 122.41 standard conditions or the State equivalent (or more stringent) conditions?	X		

List of Standard Conditions – 40 CFR 122.41

Duty to comply	Property rights	Reporting Requirements
Duty to reapply	Duty to provide information	Planned change
Need to halt or reduce activity not a defense	Inspections and entry	Anticipated noncompliance
	Monitoring and records	Transfers
Duty to mitigate	Signatory requirement	Monitoring reports
Proper O & M	Bypass	Compliance schedules
Permit actions	Upset	24-Hour reporting
		Other non-compliance

2. Does the permit contain the additional standard condition (or the State equivalent or more stringent conditions) for POTWs regarding notification of new introduction of pollutants and new industrial users [40 CFR 122.42(b)]?	X		

Part III. Signature Page

Based on a review of the data and other information submitted by the permit applicant, and the draft permit and other administrative records generated by the Department/Division and/or made available to the Department/Division, the information provided on this checklist is accurate and complete, to the best of my knowledge.

Name	Susan A. Oakes
Title	Environmental Specialist II
Signature	
Date	March 23, 2009